Utah Department of Environmental Quality Division of Drinking Water

Public Water System Inventory Report

Run Date: 08/04/2011 11:35 am

PWS ID: UTAH02020 Name: SNOWVILLE WATERWORKS

Legal Contact SNOWVILLE WATERWORKS Rating: Approved

ALLAN J MORGAN Rating Date: 11/25/2003

Address: PO BOX 694 Activity Status: Active

SNOWVILLE, UT 84336

Phone Number: 435-279-0792

City Served (Area):

County: BOX ELDER COUNTY

Gal/Day Gal/Min

System Type:CommunityLast Inv Update:03/03/2011Avg Daily Prod:Activity Status Cd:ActiveLast Snty Srv Dt:09/23/2008Total Dsgn Cap:Population:343Surveyor:RICHARD WORLEYTotal Emerg Cap:

Oper Period: 1/1 to 12/31

Contacts

Contact		Phone Numbers							
Type	Name	Title	Office	Emergency	Email Address				
AC	MORGAN, ALLAN J		435-279-0792						

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections	
Residential	Metered	0	104	
Combined	Metered	0	9	
			113 T c	- otal Svc Connection:

Storage

Total Storage: 420,000 GAL Number of Units: 2 Adequate Capacity: NO

No.	Name	Туре	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	NORTH HILL TANK	Ground	220,000 GAL	Concrete		Α	NO
ST002	SOUTH HILL TANK	Ground	200,000 GAL	Concrete	4799	Α	NO

Distribution System

Pump Type	Total Dy	n Head	Pressure	Cross	Auhority
	ft H2O	P.S.I.	Adequate	Connection	Statement
•			No		

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	NORTH HILL WELL	Active	WL	16	160 GPM	160 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS002	SNOWVILLE WELL #2	Inactive	WL			270 GPM	Yes	GW	Permanent		

^{*}Reports measured flow for wells, approved design capacity for all other sources.